



4747 East 49th Street
Phone: 216-641-6000 Fax: 216-641-5120

To: IDDE Notification
Group

From: Mario Meany

Date: 3/14/2021

**Northeast Ohio Regional Sewer District
Initial Notification Form
*Discovery of Illicit Discharge in CSO SWO
(downstream of all regulators)***

Date Found: 3/14/2021 **Time Found:** 13:20:00 AM **CSO:** O50

Receiving Water: Big Creek

Facility Name: Young Achievers

Facility Street Address: 4145 Pearl Road

Facility City: Cleveland **Facility Zip:** 44109

Facility Contact/Phone Number:

Estimated Discharge (gallons per day): 90 gpd

Description:

Performed dye test at Young Achievers, 4145 Pearl Road, and it found to be improperly connected to the Storm Water Outlet pipe tributary to CSO-050.

Contact Person: Seth Hothem

Additional Information:

Work Order #: 1802196

Investigation ID: 2015-762